



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department


March 28, 2017

Re: Intersection Improvements
Douglas County Board of Commissioners
Solicitation No. 17-001

Dear Ladies and Gentlemen,

This **Addendum No.1**, to Douglas County's Invitation to Bid for Improvements at the Intersection of Stewart Mill Rd at West Stewart Mill Rd/Yancey Rd, is hereby issued to provide clarification to the Bid in the following particulars only, and is made a part of the Bid document.

1. Does the county have a Utility Adjustment Schedule that can be provided for this project? **SEE THE ATTACHED ESTIMATED SCHEDULE**
2. GDOT requires a post installation inspection of storm drain pipes with the use of laser profile technology. Will the County require this same inspection? **YES**
3. Would the County please provide anticipated date of issuance of NTP? **30-60 DAYS AFTER BID AWARD**
4. **NOTE: The signal as provided in the plan set is not correctly shown. The attached updated plans show the correct signal installation as required by state and federal signal installation standards. This update also includes a quantity change for the "3-section, 12" signal head LED, all gloss black, plastic" from 6 units to 8 units.**



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department

Thank you for your attention to this Addendum No.1, and interest in Douglas County. Please acknowledge receipt of this addendum via, return fax, at 770.920.7219 and include this addendum and your acknowledgement in your bid/proposal package, not to be counted as a part of any page limit.

All other terms and conditions of the Bid remain the same.

Sincerely,

Bill C. Peacock

Director, Purchasing

ACKNOWLEDGEMENT

COMPANY: _____

SIGNATURE: _____

TITLE: _____ DATE: _____

We acknowledge receipt of your Addendum No. 1, Solicitation No 17-001.