

Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department


June 6, 2018

Re: Fire Station #3 Renovation (REBID)
Douglas County Board of Commissioners
Solicitation No. 18-003

Dear Ladies and Gentlemen,

This **Addendum No.1**, to Douglas County's Invitation to Bid for Renovation of the Douglas County Fire Station #3 located at 5203 Kilroy Lane Douglasville, Georgia, is hereby issued to provide clarification to the Invitation in the following particulars only, and is made a part of the Bid document.

1. Where will the Temporary Housing be located in comparison to the existing septic tank? **The group went outside and looked at the location of the existing tank and discussed possible locations for the trailer. It was decided that the best location for access and set-up cost would be to locate the trailer behind the Fire Station near the existing septic tank.**
2. Will the County or contractor be removing the existing brick on the west wall? **The contractor will be responsible for removing and cleaning the existing brick for other use. The County will be responsible for everything else.**
3. When will the County get started on performing the demo work? **The demo work will have to be coordinated with the Sheriff Office (SO) once a contractor has been selected. The Temporary Housing will have to be in place and functioning before the demo starts. The length of time to complete the work may vary depending on how many workers are available each day from the SO.**
4. Regarding the temporary housing trailer: Do you need an ADA ramp? **A ramp will not be required since it's a temporary structure.**
5. Regarding the temporary housing trailer: Do you need skirting? **Yes, skirting and tie down straps will be required.**
6. The specifications call for Hardi-board. Would you accept another concrete fiber materials with the same warranty? **Yes, a different hardi-board company can be used. They must meet the same standards and warranty and the color must also match what has been selected.**



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department

Thank you for your attention to this Addendum No.1, and interest in Douglas County. Please acknowledge receipt of this addendum via, return fax, at 770.920.7219 and include this addendum and your acknowledgement in your bid/proposal package, not to be counted as a part of any page limit.

All other terms and conditions of the Bid remain the same.

Sincerely,

Bill C. Peacock

Director, Purchasing

ACKNOWLEDGEMENT

COMPANY: _____

SIGNATURE: _____

TITLE: _____ DATE: _____

We acknowledge receipt of your Addendum No. 1, Solicitation No 18-003.