



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department

February 1, 2018

Re: Fueling Station
Douglas County Board of Commissioners
Solicitation No. 18-001

Dear Ladies and Gentlemen,

This **Addendum No.2**, to Douglas County's Request for Proposal for the Fueling Station for Douglas County, is hereby issued to provide clarification to the Request in the following particulars only, and is made a part of the Request for Proposal document.

1. Addendum No. 1, Response #19 on fiber optic cabling to FMU's. May we install Cat 5/6 Ethernet cabling instead if all cable runs are less than 300 feet? **Yes.**
2. Addendum No. 1, Response #28 on Plot Plan. May we request the plan which was attached to addendum no. 1 as a ".DWG" file? **Was that the survey? If so, I sent you a .pdf of it this morning.**
3. Addendum No. 1, Response #29 and 31 on electrical panel and location. Please confirm desired location for fuel sub-panel, we suggest it be located in the rear of the existing shop building (South end). **At the current panel location.**
4. Addendum No. 1, Response #32 on ATG location. Please confirm desired location of ATG. May we bid based on the ATG being located in the rear of the existing shop building (South end) or should we bid based on ATG being located in the office area at the North end of the building? **I would submit pricing on both locations for consideration.**
5. Addendum No. 1, Response #39 on using fire hydrant with meter. Will the County furnish the meter? If the Contractor shall furnish the meter, will the Contractor be responsible for paying for the water used? **Contractor shall furnish meter and pay for the water used.**
6. The proposed location is on a fairly decent downhill slope but the new fuel islands, canopy slab and tank slab will need to be somewhat level. Will the county raise the parking lot grade around the proposed fuel island to match the new concrete slabs or should we slope tank and canopy pads to match existing parking slope? **No it will require a Turndown Concrete Slab. Backfilled and sloped with aggregate, soil, asphalt, concrete, etc.**
7. Does the county have specific concrete specs for surface concrete pad construction? **As this is a design build project we would look at the submittals and adjust accordingly. I would suggest 6" 4000 psi with fiber and welded wire fabric reinforcing.**



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department

8. There was no mention in the bid packet regarding safety requirements, erosion control requirements, jobsite protection requirements, jobsite trailer location, safety meetings, project meetings, project management requirements, etc. Can you please define owner expectations? **All Federal, State, and Local requirements must be complied with.**
9. Please confirm the county does not want/require an engineered system with engineer stamped drawings. **The canopy should be pre-engineered. All concrete footings should be signed off by an engineer re: soil testing and footing design.**
10. The automatic tank gauging specs are incomplete and one item is wrong. Should we price what we feel is correct? **Yes.**
11. Can we use an equivalent system manufacturer that meets federal and state performance regulations? **Yes. Submit for consideration and approval.**
12. Are there any asphalt specs if asphalt needs to be replaced? "Section 2.3.14 H – The contractor shall perform asphalt paving." **No. I would suggest that aggregate base, asphalt binder and topping should be used.**

Thank you for your attention to this Addendum No.2, and interest in Douglas County. Please acknowledge receipt of this addendum via, return fax, at 770.920.7219 and include this addendum and your acknowledgement in your bid/proposal package, not to be counted as a part of any page limit.

All other terms and conditions of the Proposal remain the same.

Sincerely,

Bill C. Peacock

Director, Purchasing

ACKNOWLEDGEMENT

COMPANY: _____

SIGNATURE: _____

TITLE: _____ DATE: _____

We acknowledge receipt of your Addendum No. 2, Solicitation No 18-001.