



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department


May 29, 2018

Re: Patching, Milling, Leveling, Resurfacing, Striping and Installation of Raised Pavement Markers of Various Douglas County Roads
Douglas County Board of Commissioners
Solicitation No. 18-008

Dear Ladies and Gentlemen,

This **Addendum No.1**, to Douglas County's Invitation to Bid for Patching, Milling, Leveling, Resurfacing, Striping and Installation of Raised Pavement Markers of Various Douglas County Roads, is hereby issued to provide clarification to the Invitation in the following particulars only, and is made a part of the Invitation to Bid document.

1. Will Douglas Co. be issuing the correct Road Summary of Information that matches the (8) roads that are mapped? **To be determined.**
2. For the best pricing could Douglas Co. give the bidding contractors the total tons of Patching on each road? **Areas to be patched will be marked prior to contractor beginning work.**
3. What is the depth of Patching? **2"**
4. Will the Patch areas be marked so the contractor can use a 6.5' milling machine?
Yes
5. What type mix is Douglas Co. going to require for the Patching? **19mm**
6. How many days does the contractor have before covering the milled surfaces with asphalt? **See general notes paragraph 16**
7. Will the contractor be required to pave the turn lanes? **Yes**
8. Will the contractor be required to mill and pave into the side roads? **At Engineers discretion.**
9. Will the contractor be required to pave into the driveways or will the contractor be allowed to run the spreader gate out as they go by each driveway? **Will be allowed to run gate out as long as contractor provides good transition.**
10. Midway Rd. has the thermoplastic words STOP AHEAD AND SCHOOL. Will these be replaced? No pay item. **Lump sum traffic control**
11. Will the leveling be full width paving or spot paving? **Full width in spot locations**
12. Will the 9.5mm be TP2 at 125 lbs/sy? **Yes**
13. Will the milling be edge milling or full width milling? **Mainly edge milling, Some areas to be full width (Butt Joints, Etc)**
14. Can Douglas Co. identify the roads that will be edge milled and or full milled. This will ensure better pricing on the milling pay item. **At engineers discretion.**
15. Should the finished asphalt be flush with the curb and gutter? **Yes**
16. Section 108.08C states that the Complete Paving Operation should be completed in 30 calendar days. Isn't this project 150 calendar days from NTP?
150 calendar days
17. #18 in the General Notes states that the contractor shall be responsible for applying Soil Sterilant. Please clarify. **Will not be required.**



Douglas County Board of Commissioners

8700 Hospital Drive • Douglasville, GA 30134 • Telephone 770.920.7247 • Fax 770.920.7219

Purchasing Department

18. Will the contractor be required to replace any Traffic Signal Loops on this contract? **Yes**
19. Will the contractor be required to Adjust to Grade Manholes/Water Valves?
County will supply manhole and valve risers where needed.
20. Can the contractor place the advanced warning signs on tripods or will these signs need to be post mounted? **Post mounted**
21. Will the contractor be required to perform any testing on this project? **No**

Thank you for your attention to this Addendum No.1, and interest in Douglas County. Please acknowledge receipt of this addendum via, return fax, at 770.920.7219 and include this addendum and your acknowledgement in your bid/proposal package, not to be counted as a part of any page limit.

All other terms and conditions of the Invitation remain the same.

Sincerely,

Bill C. Peacock

Director, Purchasing

ACKNOWLEDGEMENT

COMPANY: _____

SIGNATURE: _____

TITLE: _____ DATE: _____

We acknowledge receipt of your Addendum No. 1, Solicitation No 18-008.